

“B”

**Recommended Conditions of Approval
and Final Agency Approval Memos**

**PLANNING COMMISSION HEARING – DECEMBER 15, 2021
RECOMMENDED CONDITIONS OF APPROVAL**

**Venge Vineyards Use Permit Major Modification
Application Number P19-00141-MOD
4708 Silverado Trail, Calistoga, California
APN #020-350-043**

This permit encompasses and shall be limited to the project commonly known as Venge Vineyards, located at 4708 Silverado Trail. Part I encompasses the Project Scope and general conditions pertaining to statutory and local code references, project monitoring, and the process for any future changes or activities. Part II encompasses the ongoing conditions relevant to the operation of the project. Part III encompasses the conditions relevant to construction and the prerequisites for a Final Certificate of Occupancy. It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved.

Where conditions are not applicable or relevant to this project, they shall be noted as “Reserved” and therefore have been removed.

When modifying a legally established entitlement related to this project, these conditions are not intended to be retroactive or to have any effect on existing vested rights except where specifically indicated.

PART I

1.0 PROJECT SCOPE

The permit encompasses and shall be limited to:

- 1.1 Approval to modify an existing 20,000 gallon per year winery, previously approved under Use Permit P08-00647-UP, to allow the following:
 - a. Addition of 10 new parking spaces and provision of a minimum of two bicycle parking spaces;
 - b. Increase in maximum annual permitted wine production from 20,000 to 70,000 gallons;
 - c. Visitation, tours and tasting, and a marketing plan as set forth in Conditions of Approval (COAs) Nos. 4.1 through 4.3 below;
 - d. Daily hours of operation for winery production activities shall be limited to 9:00 AM to 5:00 PM (except during crush) and visitation activities shall be limited to 9:00 AM to 5:00 PM, seven days a week;
 - e. Maximum number of employees; 5 full-time employees
 - f. Number of parking spaces; 16
 - g. Upgrade the existing wastewater system consistent with County and Regional Water Quality Control Board standards;
 - h. Improvement of the existing driveway to County standards; and

- i. Installation of a left turn lane at Silverado Trail and the project driveway.

The winery shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code (the County Code). It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved. Any expansion or change in winery use or alternative locations for fire suppression or other types of water tanks shall be approved in accordance with the County Code and may be subject to the permit modification process.

2.0 STATUTORY AND CODE SECTION REFERENCES

All references to statutes and code sections shall refer to their successor as those sections or statutes may be subsequently amended from time to time.

3.0 MONITORING COSTS

All staff costs associated with monitoring compliance with these conditions, previous permit conditions, and project revisions shall be borne by the permittee and/or property owner. Costs associated with conditions of approval and mitigation measures that require monitoring, including investigation of complaints, other than those costs related to investigation of complaints of non-compliance that are determined to be unfounded, shall be charged to the property owner or permittee. Costs shall be as established by resolution of the Board of Supervisors in accordance with the hourly consulting rate established at the time of the monitoring and shall include maintenance of a \$500 deposit for construction compliance monitoring that shall be retained until issuance of a Final Certificate of Occupancy. Violations of conditions of approval or mitigation measures caused by the permittee's contractors, employees, and/or guests are the responsibility of the permittee.

The Planning Commission may implement an audit program if compliance deficiencies are noted. If evidence of a compliance deficiency is found to exist by the Planning Commission at some time in the future, the Planning Commission may institute the program at the applicant's expense (including requiring a deposit of funds in an amount determined by the Commission) as needed until compliance assurance is achieved. The Planning Commission may also use the data, if so warranted, to commence revocation proceedings in accordance with the County Code.

PART II

4.0 OPERATIONAL CHARACTERISTICS OF THE PROJECT

Permittee shall comply with the following during operation of the winery:

4.1 GENERAL PROVISIONS

Consistent with the County Code, tours and tastings and marketing may occur at a winery only where such activities are accessory and "clearly incidental, related, and subordinate to the primary operation of the winery as a production facility."

Tours and tastings (defined below) may include food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery and is incidental to the tasting of wine. Food service may not involve menu options and meal service such that the winery functions as a café or restaurant.

Retail sales of wine shall be permitted as set forth in the County Code.

4.2 TOURS AND TASTINGS/VISITATION

Tours and tastings shall be by appointment only and shall be limited to the following:

- a. Frequency: seven days per week, Monday through Sunday
- b. Maximum number of persons per day: 19
- c. Maximum number of persons per week: 133
- d. Hours of visitation: 9:00 am to 5:00 pm
- e. On days when marketing events with greater than 10 visitors are occurring, no tours and tastings shall occur.

“Tours and tastings” means tours of the winery and/or tastings of wine, where such tours and tastings are limited to persons who have made unsolicited prior appointments for tours or tastings. To the maximum extent feasible, scheduling of visitors shall not occur during peak travel times of 4:00 PM to 5:00 PM, Monday through Friday and 1:00 PM to 2:00 PM, Saturday and Sunday.

A log book (or similar record) shall be maintained to document the number of visitors to the winery (for either tours and tastings or marketing events), and the dates of the visits. This record of visitors shall be made available to the Planning, Building and Environmental Services (PBES) Department upon request.

4.3 MARKETING

Marketing events shall be limited to the following:

- a. **Type 1**
 1. Frequency: 24 times per year
 2. Maximum number of persons: 10
 3. Time of Day: 11:00 am to 10:00 pm
- b. **Type 2**
 1. Frequency: 12 times per year
 2. Maximum number of persons: 30
 3. Time of Day: 11:00 am to 10:00 pm
 4. These events shall be scheduled to not start or end during the weekday PM hour (4:00 PM to 5:00 PM) or weekend midday peak hour (1:00 PM to 2:00 PM) on weekend days.
- c. Tours and tastings and marketing events shall not occur upon issuance of a Red Flag Warning^[1] by the National Weather Service or Napa County

Office of Emergency Services, or upon issuance of a Public Safety Power Shutoff (PSPS) Warning by Pacific Gas and Electric (PG&E), when such Warnings have been issued affecting the subject parcel of this use permit. If Warnings are issued within Napa County, marketing events may take place only if the Project Parcel of this use permit is not located within the boundaries of the Warning order. If a marketing event is occurring at the time a Red Flag Warning or PSPS Warning is issued and takes effect, the event shall be terminated and all attendees and non-essential personnel shall be expeditiously directed off of the property.

"Marketing of wine" means any activity of a winery which is conducted at the winery on a prearranged basis for the education and development of customers and potential customers with respect to wine which can be sold at the winery on a retail basis pursuant to the County Code. Marketing of wine may include cultural and social events directly related to the education and development of customers and potential customers provided such events are clearly incidental, related and subordinate to the primary use of the winery. Marketing of wine may include food service, including food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery.

Business events are similar to cultural and social events, in that they will only be considered as "marketing of wine" if they are directly related to the education and development of customers and potential customers of the winery and are part of a marketing plan approved as part of the winery's Use Permit. To be considered directly related to the education and development of customers or potential customers of the winery, business events must be conducted at no charge except to the extent of cost recovery, and any business content unrelated to wine must be limited.

Careful consideration shall be given to the intent of the event, the proportion of the business event's non-wine-related content, and the intensity of the overall marketing plan (County Code).

All marketing event activity, excluding quiet clean-up, shall cease by 10:00 pm. If any event is held which will exceed the available on-site parking, the permittee shall prepare an event-specific parking plan which may include, but not be limited to, valet service or off-site parking and shuttle service to the winery.

Auction Napa Valley (ANV) events need not be included in a participating winery's marketing plan because they are covered by ANV's Category 5 Temporary Permit. The winery may utilize any ANV event authorized in this permit for another charitable event of similar size.

¹ Red Flag Warnings are issued for weather events that may result in extreme fire behavior that will occur within 24 hours, to alert fire departments of the onset, or possible onset, of critical weather and dry conditions that could lead to rapid or dramatic increases in wildfire activity.

4.4 ON-PREMISES CONSUMPTION **[RESERVED]**

4.5 RESIDENCE OR NON-WINERY STRUCTURES

Unless specifically authorized by this permit or a previously approved permit, the existing single-family residence shall not be used for commercial purposes or in conjunction with the operation and/or visitation/marketing program for the winery. If the residence is rented, it shall only be rented for periods of 30 days or more, pursuant to the County Code.

4.6 GRAPE SOURCE

At least 75% of the grapes used to make the winery's still wine or the still wine used by the winery to make sparkling wine shall be grown within Napa County. The permittee shall keep records of annual production documenting the source of grapes to verify that 75% of the annual production is from Napa County grapes. The report shall recognize the Agriculture Commission's format for County of origin of grapes and juice used in the Winery Production Process. The report shall be provided to the PBES Department upon request, but shall be considered proprietary information and not available to the public.

4.7 COMPLIANCE REVIEW

Permittee shall obtain and maintain all permits (use permits and modifications) and licenses from the California Department of Alcoholic Beverage Control (ABC) and United States Tax and Trade Bureau (TTB), and California Department of Food and Agriculture (CDFA) Grape Crush Inquiry data, all of which are required to produce and sell wine. In the event the required ABC and/or TTB permits and/or licenses are suspended or revoked, permittee shall cease marketing events and tours and tastings until such time as those ABC and/or TTB permits and licenses are reinstated.

Visitation log books, visitor reports, custom crush client records, and any additional documentation determined by Staff to be necessary to evaluate compliance may be requested by the County for any code compliance. The permittee (and their successors) shall be required to participate fully in the winery code compliance review process.

4.8 RENTAL/LEASING

No winery facilities, or portions thereof, including, without limitation, any kitchens, barrel storage areas, or warehousing space, shall be rented, leased, or used by entities other than persons producing and/or storing wine at the winery, such as alternating proprietors and custom producers, except as may be specifically authorized in this Permit or pursuant to the Temporary Events Ordinance (County Code Chapter 5.36).

4.9 GROUND WATER MANAGEMENT - WELLS

This condition is implemented jointly by the Public Works and PBES Departments:

The permittee shall be required (at the permittee's expense) to record well monitoring data (specifically, static water level no less than quarterly, and the volume of water no less than monthly). Such data will be provided to the County, if the PBES Director determines that substantial evidence¹ indicates that water usage at the winery is affecting, or would potentially affect, groundwater supplies or nearby wells. If data indicates the need for additional monitoring, and if the applicant is unable to secure monitoring access to neighboring wells, onsite monitoring wells may need to be established to gauge potential impacts on the groundwater resource utilized for the project. Water usage shall be minimized by use of best available control technology and best water management conservation practices.

In order to support the County's groundwater monitoring program, well monitoring data as discussed above will be provided to the County if the Director of Public Works determines that such data could be useful in supporting the County's groundwater monitoring program. The project well will be made available for inclusion in the groundwater monitoring network if the Director of Public Works determines that the well could be useful in supporting the program.

In the event that changed circumstances or significant new information provide substantial evidence¹ that the groundwater system referenced in the Use Permit would significantly affect the groundwater basin, the PBES Director shall be authorized to recommend additional reasonable conditions on the permittee, or revocation of this permit, as necessary to meet the requirements of the County Code and to protect public health, safety, and welfare.

4.10 AMPLIFIED MUSIC

There shall be no amplified sound system or amplified music utilized outside of approved, enclosed, winery buildings.

4.11 TRAFFIC

To the maximum extent feasible, scheduling of reoccurring vehicle trips to and from the site for employees and deliveries shall not occur during peak travel times (2:30 PM to 3:30 PM, Monday through Friday and 3:00 PM to 4:00 PM, Saturday and Sunday). All road improvements on private property required per Engineering Services shall be maintained in good working condition and in accordance with the Napa County Roads and Streets Standards.

¹ Substantial evidence is defined by case law as evidence that is of ponderable legal significance, reasonable in nature, credible and of solid value. The following constitute substantial evidence: facts, reasonable assumptions predicated on facts; and expert opinions supported by facts. Argument, speculation, unsubstantiated opinion or narrative, or clearly inaccurate or erroneous information do not constitute substantial evidence.

4.12 PARKING

The location of visitor parking and truck loading zone areas shall be identified along with proposed circulation and traffic control signage (if any).

Parking shall be limited to approved parking spaces only and shall not occur along access or public roads or in other locations except during harvest activities and approved marketing events. In no case shall parking impede emergency vehicle access or public roads.

4.13 BUILDING DIVISION – USE OR OCCUPANCY CHANGES

Please contact the Building Division with any questions regarding the following:

In accordance with the California Building Code (CBC), no change shall be made in the use of occupancy of an existing building unless the building is made to comply with the requirements of the current CBC for a new building.

4.14 FIRE DEPARTMENT – TEMPORARY STRUCTURES

Please contact the Fire Department with any questions regarding the following:

The permittee and/or designee shall obtain a tent permit from the Fire Department for any temporary structures utilized for authorized marketing events allowed per COA No. 4.3 above.

4.15 NAPA COUNTY MOSQUITO ABATEMENT PROGRAM **[RESERVED]**

4.16 GENERAL PROPERTY MAINTENANCE – LIGHTING, LANDSCAPING, PAINTING, OUTDOOR EQUIPMENT STORAGE, AND TRASH ENCLOSURE AREAS

- a. All lighting shall be permanently maintained in accordance with the lighting and building plans approved by the County. Lighting utilized during harvest activities is exempt from this requirement.
- b. All landscaping and outdoor screening, storage, and utility structures shall be permanently maintained in accordance with the landscaping and building plans approved by the County. No stored items shall exceed the height of the screening. Exterior winery equipment shall be maintained so as to not create a noise disturbance or exceed noise thresholds in the County Code.
- c. The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division prior to any change in paint colors that differs from the approved building permit. Highly reflective surfaces are prohibited.
- d. Designated trash enclosure areas shall be made available and properly maintained for intended use.

4.17 NO TEMPORARY SIGNS

Temporary off-site signage, such as “A-Frame” signs, is prohibited.

4.18 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – OPERATIONAL CONDITIONS

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies’ requirements. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division operational conditions as stated in their Memorandum dated September 7, 2021.
- b. Environmental Health Division operational conditions as stated in their Memorandum dated June 25, 2020.
- c. Department of Public Works operational conditions as stated in their Memorandum dated October 26, 2021.
- d. Fire Department operational conditions as stated in their Inter-Office Memo dated November 18, 2021.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify this permit.

4.19 OPERATIONAL MITIGATION MEASURES **[RESERVED]**

4.20 OTHER CONDITIONS APPLICABLE TO THE OPERATIONAL ASPECTS OF THE PROJECT

- a. Prior to commencement of operational changes in this major modification, including increasing the number of employees, or holding modified marketing activities, the applicant shall submit evidence to the Planning Division that all site and/or operational improvements required by County Divisions are complete. Site or operational improvements include; compliance with the Napa County Roads and Streets Standards; and installation of the updated wastewater system improvements as identified in the Wastewater Feasibility Study prepared by Applied Civil Engineering, dated June 2, 2020.

4.21 PREVIOUS CONDITIONS

The permittee shall comply with the following previous conditions of approval for the winery use as consolidated into the attached document as Exhibit A. To the extent there is a conflict between a previous condition of approval identified in the attached document and these conditions, the more stringent condition shall control.

PART III

5.0 PREREQUISITE FOR ISSUANCE OF PERMITS

5.1 PAYMENT OF FEES

No building, grading or sewage disposal permits shall be issued or other permits authorized until all accrued planning permit processing fees have been paid in full. This includes all fees associated with plan check and building inspections, associated development impact fees established by County Ordinance or Resolution, and the Napa County Affordable Housing Mitigation Fee in accordance with County Code.

6.0 GRADING/DEMOLITION/ENVIRONMENTAL/BUILDING PERMIT/OTHER PERMIT PREREQUISITES

Permittee shall comply with the following with the submittal of a grading, demolition, environmental, building and/or other applicable permit applications.

6.1 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – PLAN REVIEW, CONSTRUCTION AND PREOCCUPANCY CONDITIONS

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies' requirements. The permittee shall comply with all applicable building codes, zoning standards, and requirements of County Divisions, Departments and Agencies at the time of submittal and may be subject to change. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated September 7, 2021.
- b. Environmental Health Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated June 25, 2020.
- c. Department of Public Works plan review/construction/ preoccupancy conditions as stated in their Memorandum dated October 26, 2021.
- d. Fire Department plan review/construction/ preoccupancy conditions as stated in their Inter-Office Memo dated November 18, 2021.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify the permit.

6.2 BUILDING DIVISION – GENERAL CONDITIONS

- a. A building permit shall be obtained for all construction occurring on the site not otherwise exempt by the California Building Code (CBC) or any State or local amendment adopted thereto.
- b. If there are any existing structures and/or buildings on the property that will need to be removed to accommodate construction activities, a separate demolition permit shall be required from the Building Division prior to removal. The permittee shall provide a “J” number from the Bay Area Air Quality Management District (BAAQMD) at the time the permittee applies for a demolition permit if applicable.
- c. All areas of newly designed and newly constructed buildings, facilities and on-site improvements must comply with the CBC accessibility requirements, as well as, American with Disability Act requirements when applicable. When alterations or additions are made to existing buildings or facilities, an accessible path of travel to the specific area of alteration or addition shall be provided as required per the CBC.

6.3 LIGHTING – PLAN SUBMITTAL

- a. Two (2) copies of a detailed lighting plan showing the location and specifications for all lighting fixtures to be installed on the property shall be submitted for Planning Division review and approval. All lighting shall comply with the CBC.
- b. All exterior lighting, including landscape lighting, shall be shielded and directed downward, shall be located as low to the ground as possible, shall be the minimum necessary for security, safety, or operations; on timers; and shall incorporate the use of motion detection sensors to the greatest extent practical. All lighting shall be shielded or placed such that it does not shine directly on adjacent properties or impact vehicles on adjacent streets. No flood-lighting or sodium lighting of the building is permitted, including architectural highlighting and spotting. Low-level lighting shall be utilized in parking areas as opposed to elevated high-intensity light standards. Lighting utilized during harvest activities is exempt from this requirement.

6.4 LANDSCAPING – PLAN SUBMITTAL

- a. Two (2) copies of a detailed final landscaping and irrigation plan, including parking details, shall be submitted with the building permit application package for the Planning Division’s review and approval prior to the issuance of any building permit associated with this Use Permit. The plan shall be prepared pursuant to the County’s Water Efficient Landscape Ordinance (Chapter 18.118 of the County Code) requirements in effect at the time of building permit application submittal, as applicable, and shall indicate the names and locations of all plant materials to be used along with their method of maintenance.
- b. Plant materials shall be purchased locally when practical, and to the greatest extent possible, the plant materials shall be the same native plants found in Napa County. The Agricultural Commissioner’s office shall be

notified of all impending deliveries of live plants with points of origin outside of Napa County.

- c. No trees greater than 6" diameter at breast height shall be removed, except for those identified on the submitted site plan. Any Oak trees removed as a result of the project shall be replaced at a 2:1 ratio and shown on the landscaping plans for the Planning Division's review and approval. Trees to be retained shall be protected during construction by fencing securely installed at the outer most dripline of the tree or trees. Such fencing shall be maintained throughout the duration of the work undertaken in connection with the winery development/construction. In no case shall construction material, debris or vehicles be stored in the fenced tree protection area.
- d. Evergreen screening shall be installed between the industrial portions of the operation (e.g. tanks, crushing area, parking area, etc.) and any off-site residence from which these areas can be viewed.

6.5 COLORS

The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division in conjunction with building permit review and/or prior to painting the building. Highly reflective surfaces are prohibited.

6.6 OUTDOOR STORAGE/SCREENING/UTILITIES

- a. Details of outdoor storage areas and structures shall be included on the building and landscape plans. All outdoor storage of winery equipment shall be screened from the view of residences of adjacent properties by a visual barrier consisting of fencing or dense landscaping. No stored item shall exceed the height of the screening. Water and fuel tanks, and similar structures, shall be screened to the extent practical so as to not be visible from public roads and adjacent parcels.
- b. New utility lines required for this project that are visible from any designated scenic transportation route (see Community Character Element of the General Plan and the County Code) shall be placed underground or in an equivalent manner be made virtually invisible from the subject roadway.
- c. Exterior winery equipment shall be located, enclosed or muffled so as not to exceed noise thresholds in the County Code.

6.7 TRASH ENCLOSURES

Adequate area must be provided for collection and loading of garbage and recyclables generated by the project. The applicant must work with the franchised garbage hauler for the service area in which they are located, in order to determine the area and the pedestrian and vehicle access needed for the collection site. The garbage and recycling enclosure shall meet the minimum enclosure requirements

established by staff and the franchised hauler, which shall be included in the building permit submittal.

6.8 ADDRESSING

All project site addresses shall be determined by the PBES Director, and be reviewed and approved by the United States Post Office. The PBES Director reserves the right to issue or re-issue an appropriate situs address at the time of issuance of any building permit to ensure proper identification and sequencing of I numbers. For multi-tenant or multiple structure projects, this includes building permits for later building modifications or tenant improvements.

6.9 HISTORIC RESOURCES **[RESERVED]**

6.10 DEMOLITION ACTIVITIES **[RESERVED]**

6.11 VIEWSHED – EXECUTION OF USE RESTRICTION **[RESERVED]**

6.12 PERMIT PREREQUISITE MITIGATION MEASURES

The permittee shall comply with the following permit prerequisite mitigation measures identified in the adopted Initial Study/Mitigated Negative Declaration and Project Revision Statement/Mitigation Monitoring and Reporting Program prepared for the project:

- a. **MM TRI-1:** Prior to commencement of construction of project improvements at the project site, the permittee shall coordinate with an archaeological monitor and a representative of Middletown Rancheria. Pre-construction coordination shall, at a minimum, include the following:
 - a. Submittal of copies of grading plans to the archaeological monitor and tribal representatives, concurrently with submittal of the grading permit application to the Napa County Planning, Building & Environmental Services (PBES) Department;
 - b. Execution of a Standard Monitoring Agreement with Middletown Rancheria;
 - c. Training of construction field crews, by an archaeological monitor and tribal representative, of the potential for presence of Native American resources on the property, the potential types of resources that could be found on-site, and the procedures to follow in the event of discovery of such resources;
 - d. The permittee must meet and confer with the Middletown Rancheria at least 45 days prior to commencing ground disturbance activities on the site to address notification, protection, treatment, care and handling of tribal cultural resources potentially discovered or disturbed during ground disturbance activities of the project. All potential cultural resources unearthed by the permittee by project activities shall be evaluated by the representative of Middletown Rancheria. The Tribe must have an opportunity to inspect and determine the nature of the resource and the best course of action for avoidance, protection,

and/or treatment of tribal cultural resources to the extent permitted by law. If the resource is determined to be a tribal cultural resource of value to the Tribe, the Tribe will coordinate with the permittee to establish appropriate treatment and disposition of the resources with appropriate dignity which may include reburial or preservation of resources. The permittee must facilitate and ensure that the determination of treatment and disposition by the Tribe is followed to the extent permitted by law. No laboratory studies, scientific analysis, curation or video recording are permitted for tribal cultural resources without the prior written consent of the Tribe; and

- e. Presence of an archaeological monitor and tribal representative on-site during initial rough grading of improvements (driveway widening) on the Venge Vineyards parcel.

Method of Monitoring: Concurrently with submittal of the grading application for Venge Vineyards parcel improvements to Engineering and Building staff of PBES, the permittee shall submit confirmation of submittal of the grading plans to the archaeological monitor and tribal representative previously identified. If the permittee neglects to submit such confirmation to PBES, then Planning staff of PBES will convey a copy of the plans to the archaeological monitor and tribal representatives upon receipt of the grading permit application.

Responsible Agency: PBES

6.13 PARCEL CHANGE REQUIREMENTS **[RESERVED]**

6.14 FINAL MAPS **[RESERVED]**

6.15 OTHER CONDITIONS APPLICABLE TO THE PROJECT PERMITTING PROCESS **[RESERVED]**

7.0 PROJECT CONSTRUCTION

Permittee shall comply with the following during project construction:

7.1 SITE IMPROVEMENTS

Please contact Engineering Services with any questions regarding the following.

a. GRADING AND SPOILS

All grading and spoils generated by construction of the project facilities shall be managed per Engineering Services direction. Alternative locations for spoils are permitted, subject to review and approval by the PBES Director, when such alternative locations do not change the overall concept, and do not conflict with any environmental mitigation measures or conditions of approval.

b. DUST CONTROL

Water and/or dust palliatives shall be applied in sufficient quantities during grading and other ground disturbing activities on-site to minimize the

amount of dust produced. Outdoor construction activities shall not occur when average wind speeds exceed 20 mph.

c. AIR QUALITY

During all construction activities the permittee shall comply with the most current version of BAAQMD Basic Construction Best Management Practices including but not limited to the following, as applicable:

1. Post a publicly visible sign with the telephone number and person to contact at the lead agency regarding dust complaints. The BAAQMD's phone number shall also be visible.
2. Water all exposed surfaces (e.g., parking areas, staging areas, soil piles, grading areas, and unpaved access roads) two times per day.
3. Cover all haul trucks transporting soil, sand, or other loose material off-site.
4. Remove all visible mud or dirt traced onto adjacent public roads by using wet power vacuum street sweepers at least once per day. The use of dry power sweeping is prohibited.
5. All vehicle speeds on unpaved roads shall be limited to 15 mph.
6. All roadways, driveways, and sidewalks to be paved shall be completed as soon as possible. Building pads shall be laid as soon as possible after grading unless seeding or soil binders are used.
7. Idling times shall be minimized either by shutting off equipment when not in use or reducing the maximum idling time to five (5) minutes (as required by State Regulations). Clear signage shall be provided for construction workers at all access points.
8. All construction equipment shall be maintained and properly tuned in accordance with manufacturer's specifications. All equipment shall be checked by a certified visible emissions evaluator. Any portable engines greater than 50 horsepower or associated equipment operated within the BAAQMD's jurisdiction shall have either a California Air Resources Board (ARB) registration Portable Equipment Registration Program (PERP) or a BAAQMD permit. For general information regarding the certified visible emissions evaluator or the registration program, visit the ARB FAQ http://www.arb.ca.gov/portable/perp/perpfact_04-16-15.pdf or the PERP website <http://www.arb.ca.gov/portable/portable.htm>.

d. STORM WATER CONTROL

The permittee shall comply with all construction and post-construction storm water pollution prevention protocols as required by the County

7.2 ARCHEOLOGICAL FINDING

In the event that archeological artifacts or human remains are discovered during construction, work shall cease in a 50-foot radius surrounding the area of discovery. The permittee shall contact the PBES Department for further guidance, which will likely include the requirement for the permittee to hire a qualified professional to analyze the artifacts encountered and to determine if additional measures are required.

If human remains are encountered during project development, all work in the vicinity must be halted, and the Napa County Coroner informed, so that the Coroner can determine if an investigation of the cause of death is required, and if the remains are of Native American origin. If the remains are of Native American origin, the permittee shall comply with the requirements of Public Resources Code Section 5097.98.

7.3 CONSTRUCTION NOISE

Construction noise shall be minimized to the greatest extent practical and feasible under State and local safety laws, consistent with construction noise levels permitted by the General Plan Community Character Element and the County Noise Ordinance. Construction equipment muffling and hours of operation shall be in compliance with the County Code. Equipment shall be shut down when not in use. Construction equipment shall normally be staged, loaded, and unloaded on the project site, if at all practicable. If project terrain or access road conditions require construction equipment to be staged, loaded, or unloaded off the project site (such as on a neighboring road or at the base of a hill), such activities shall only occur daily between the hours of 8 am to 5 pm.

7.4 CONSTRUCTION MITIGATION MEASURES **[RESERVED]**

7.5 OTHER CONSTRUCTION CONDITIONS APPLICABLE TO THE PROJECT PROPOSAL **[RESERVED]**

8.0 TEMPORARY CERTIFICATE OF OCCUPANCY - PREREQUISITES

A Temporary Certificate of Occupancy (TCO) may be granted pursuant to the County Code to allow the commencement of production activities prior to completion of all project improvements. Permittee shall comply with the following before a TCO is granted:

8.1 TEMPORARY OCCUPANCY

All life and safety conditions shall be addressed prior to issuance of a TCO by the County Building Official. TCOs shall not be used for the occupancy of hospitality buildings and shall not exceed the maximum time allowed by the County Code which is 180 days. Departments and/or agencies with jurisdiction over the project are authorized as part of the TCO process to require a security deposit or other financial instrument to guarantee completion of unfinished improvements.

9.0 FINAL CERTIFICATE OF OCCUPANCY – PREREQUISITES

Permittee shall comply with the following before a Final Certificate of Occupancy is granted by the County Building Official, which upon granting, authorizes all use permit activities to commence.

9.1 FINAL OCCUPANCY

All project improvements, including compliance with applicable codes, conditions, and requirements of all Departments and Agencies with jurisdiction over the project, shall be completed.

9.2 SIGNS

Detailed plans, including elevations, materials, color, and lighting for any winery identification or directional signs shall be submitted to the Department for administrative review and approval prior to installation. Administrative review and approval is not required if signage to be installed is consistent with signage plans submitted, reviewed and approved as part of this permit approval. All signs shall meet the design standards as set forth in the County Code. At least one legible sign shall be placed at the property entrance with the words "Tours and Tasting by Prior Appointment Only" to inform the public of same. Any off-site signs allowed shall be in conformance with the County Code.

9.3 GATES/ENTRY STRUCTURES

Any gate installed at the winery entrance shall be reviewed by the PBES Department and the Fire Department to assure that the design allows large vehicles, such as motorhomes, to turn around if the gate is closed without backing into the public roadway, and that fire suppression access is available at all times. If the gate is part of an entry structure an additional permit shall be required pursuant to the County Code and in accordance with the Napa County Roads and Street Standards. A separate entry structure permit is not required if the entry structure is consistent with entry structure plans submitted, reviewed, and approved as part of this permit approval.

9.4 LANDSCAPING

Landscaping shall be installed in accordance with the approved landscaping plan.

9.5 ROAD OR TRAFFIC IMPROVEMENT REQUIREMENTS

The permittee shall construct a left-turn lane on Silverado Trail at the project entrance. The design of the left-turn lane shall be submitted to the Public Works Department for review and approval. The left-turn lane shall be designed in substantial conformance with the submitted site plan, and other submittal materials and shall comply with all requirements of the County Code and Napa County Road and Street Standards.

9.6 DEMOLITION ACTIVITIES [RESERVED]

9.7 GRADING SPOILS

All spoils shall be removed in accordance with the approved grading permit and/or building permit.

- 9.8 MITIGATION MEASURES APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY **[RESERVED]**
- 9.9 OTHER CONDITIONS APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY **[RESERVED]**

Exhibit A

**Venge Vineyards
Application Number P19-00141-MOD
4708 Silverado Trail, Calistoga, California
APN #020-350-043**

PREVIOUS CONDITIONS

4.21 The permittee shall comply with the following previous conditions of approval for the facility as consolidated in this document. To the extent there is a conflict between a previous condition of approval identified in this document and the Recommended Conditions of Approval, the more stringent condition shall control.

A. USE PERMIT NO. P08-00647

COA No. 1: Scope

COA No. 1: Scope

- Establishment of a new, 20,000 gallon maximum per year winery (consistent with the Napa County Winery Production Process);
- Conversion of an existing 2,800 square foot residence to an administrative office / hospitality building;
- Construction of a 3,600 square foot barn-style production and fermentation building;
- Construction of up to 9,000 square feet of barrel storage either within a cave system or, in lieu of the cave system, by expanding the production building to accommodate the needed barrel storage for a winery totaling a maximum of 15,400 square feet (See Grading and Spoils condition of approval below);
- Construction of 3,324 square feet of outdoor, uncovered work areas;
- Two full-time and two part-time employees;
- Six parking spaces (including one ADA-accessible space);
- Tours and tasting by prior appointment only with twenty visitors per day and a maximum of 140 visitors per week;
- A marketing plan with: three private food and wine tasting events per year with 10 persons per event; five private food and wine tasting events per year with 30 persons per event; and participation in the Napa Valley Wine Auction Event as a Category 5 Temporary Event;
- Installation of one water tank totaling 12,000 gallons for fire protection;
- Improvements to the existing standard gravity distribution type septic system for process and sanitary winery wastewater;
- Civil improvements to widen the existing private road to the winery site and include the following additional improvements:

- 1) Installation of a deceleration taper that shall begin at the edge of pavement in accordance with the Napa County Road and Street Standards;
 - 2) Provision in the required landscaping Plan for clearing and maintenance of vegetation at the entrance from Silverado Trail (**See Condition #8: landscaping/ Parking); and,
 - 3) Installation of a winery identification sign in accordance with the Napa County Sign Ordinance (*See Condition #5: Signs); and,
- Approval of the above named Exception to the Napa County Road and Street Standards.

The winery shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code. It is the responsibility of the applicant to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved. Any expansion or changes in use shall be in accordance with Section 18.124.130 of the Napa County Code and may be subject to the Use Permit modification process.

B. USE PERMIT MINOR MODIFICATION NO. P13-00047-MM

COA No. 1: Scope

Construction of a 3,348 square foot structure for barrel and winery equipment storage.

No other changes are being requested. There will be no increase in employees, visitors or production capacity. There will be no changes in hours of operation.

The winery shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code. It is the responsibility of the applicant to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved. Any expansion or changes in use shall be by the approved in accordance with Section 18.124.130 of the Napa County Code and may be subject to the Use Permit modification process.



A Tradition of Stewardship
A Commitment to Service

Planning, Building & Environmental Services

1195 Third Street, Suite 210
Napa, CA 94559
www.countyofnapa.org

David Morrison
Director

MEMORANDUM

To: Jason Hade, Planning	From: Raulton Haye, Engineering
Date: September 7, 2021	Re: P19-00141 Venge Winery Use Modification APN: 020-350-043

The Engineering Division has reviewed the use permit application P19-00141 for the Venge Winery located on assessor’s parcel number 020-350-043. Based upon the information provided in the application, Engineering finds the application **complete** and recommends the following conditions of approval:

RECOMMENDED APPROVAL CONDITIONS:

OPERATIONAL CHARACTERISTICS

1. The facility is designated as a discharger that discharges stormwater associated with industrial activity to waters of the United States. Therefore, the facility shall maintain or apply for coverage under the State Water Resources Control Board’s Industrial General Permit (IGP), including meeting all applicable provision and protocols of the IGP. If the facility fails to meet the discharge prohibitions of the IGP, Napa County may require the facility to make the necessary improvements to eliminate all exposures to stormwater of the pollutant(s) for which the water body is impaired.

PREREQUISITES FOR ISSUANCE OF PERMITS

2. Any roadway, access driveway, and parking areas, proposed new or reconstructed shall meet the requirements as outlined in the latest edition of the Napa County Road & Street Standards for Commercial development at the time of use permit approval. The property owner shall obtain a grading permit for all proposed roadway improvements.
3. All on site civil improvements including but not limited to the excavation, fill, general grading, drainage, curb, gutter, surface drainage, storm drainage, parking and drive isles, shall be constructed according to plans prepared by a registered civil engineer, which will be reviewed and approved by the Engineering Division of the Napa County Planning, Building, and Environmental Services Department (PBES) **prior to the commencement** of any on site land preparation or construction. Plans shall be wet signed and submitted with the building and/or grading permit documents at the time of permit application. A plan check fee will apply.

4. Grading and drainage improvements shall be constructed according to the current Napa County Road and Street Standards, Chapter 16.28 of the Napa County Code, and Appendix J of the California Building Code.
5. **Prior to issuance of a building permit** the owner shall submit the necessary documents for Erosion Control as determined by the area of disturbance of the proposed development in accordance with the Napa Countywide Stormwater Pollution Prevention program Erosion and Sediment Control Plan Guidance for Applicant and Review Staff dated December 2014.
6. **Prior to issuance of a building permit** the owner shall prepare a Regulated Project Stormwater Control Plan (SCP) in accordance with the latest edition of the BASMAA Post-Construction Manual for review and approval by the Engineering Division in PBES.
7. **Prior to issuance of a building permit**, an Operation and Maintenance Plan shall be submitted and tentatively approved by the Engineering Division in PBES. **Before final occupancy** the property owner must legally record the "Operation and Maintenance Agreement", approved by the Engineering Division in PBES.

PREREQUISITES FOR TEMPORARY CERTIFICATE OF OCCUPANCY

8. All roadway improvements shall be completed **prior to execution** of any new entitlements approved under this Use Permit Modification. **** If no temporary occupancy is requested, then this becomes a requirement prior to final occupancy.**

PREREQUISITES FOR FINAL CERTIFICATION OF OCCUPANCY

9. Site shall be completely stabilized to the satisfaction of the County Engineer prior to Final Occupancy.

Any changes in use may necessitate additional conditions for approval.

If you have any questions regarding the above items, please contact Raulton Haye from Napa County Planning, Building, and Environmental Services Department, Engineering Division, at (707)253-4621 or by email at Rauton.Haye@countyofnapa.org



A Tradition of Stewardship
A Commitment to Service

Planning, Building & Environmental Services

1195 Third Street, Suite 210
Napa, CA 94559
www.countyofnapa.org

David Morrison
Director

MEMORANDUM

To: Jason Hade, Planner III	From: Darell Choate EHS
Date: June 25, 2020	Re: Use Permit Modification for Venge Vineyards 4708 Silverado Trail, Calistoga Assessor Parcel # 020-350-043-000 Permit# P19-00141

Environmental Health Division staff has reviewed an application for Venge Vineyards. This Division has no objection to approval of the application with the following conditions of approval:

1. A sewage system installation permit for the septic system addition must be applied for within 60 days of use permit approval. To secure the installation, the applicant must submit plans with a plan check fee to this Division for review and approval. The plans must show the location of the proposed septic system addition relative to the proposed project and other structures, the required 100% expansion area, the proposed trench detail, the location of the site evaluation soil profile pits and all other site features such as storm drainage, wells, roads, slope, etc. The plans must be drawn to scale.
2. The use of the absorption field/drain field area shall be restricted to activities which will not contribute to compaction of the soil with consequent reduction in soil aeration. Activities which must be avoided in the area of the septic system include equipment storage, traffic, parking, pavement, livestock, etc.
3. Please be advised-requirements for process wastewater treatment systems in Napa County are being reviewed and may be modified to comply with Regional Water Quality Control Board (RWQCB) minimum standards. The owner will have to comply with process wastewater system requirements in place at the time the application for a building permit is filed and the sewage installation permit is secured.



A Tradition of Stewardship
A Commitment to Service

Department of Public Works

1195 Third Street, Suite 101
Napa, CA 94559-3092
www.countyofnapa.org/publicworks

Main: (707) 253-4351
Fax: (707) 253-4627

Steven Lederer
Director

MEMORANDUM

To: PBES Staff	From: Ahsan Kazmi, P.E. Senior Traffic Engineer
Date: September 16, 2021 Updated: October 26, 2021	Re: Venge Vineyards (P19-00141) Conditions of Approval

This memorandum on the Conditions of Approval is prepared at the request of Planning, Building, and Environmental Services (PBES) staff regarding the Use Permit Modification Application # P19-00141, APN# 020-350-043, for the proposed Venge Vineyards, located at 4708 Silverado Trail in the County of Napa.

In preparation of this memorandum, we have reviewed the *Focused Traffic and VMT Analysis for the Venge Vineyards Use Modification Project*, dated April 7, 2021, GHD.

After careful evaluation and review of the document, we believe that the report provides sufficient information to develop conditions for the project.

The Department of Public Works established the following conditions of approval related to the Use Permit Application Number P19-00141:

Left Turn Lane:

1. The project applicant/permittee shall add a northbound left-turn lane on Silverado Trail at the Project Driveway to reduce delays and further enhance safety conditions at the intersection. The applicant has tried but has been unable to obtain right of way from a neighboring property which would allow a fully compliant left turn lane. Using the existing right of way, and by moving/modifying the drainage and utility poles as needed to achieve existing bike lane width but not less than 6', the applicant shall work with the County's Senior Traffic Engineer to install the most code compliant left turn lane as practical. The left turn lane shall be installed before issuance of Building and/or Occupancy Permit.

Marketing

2. The project applicant/permittee shall not exceed the maximum number of visitors of 19 per day.
3. The project applicant/permittee shall not exceed five full-time employees.

Transportation Demand Management (TDM) Program

4. The project applicant/permittee shall provide a Transportation Demand Management (TDM) plan with the measures that will be implemented in order to meet the County's greenhouse gases emission reduction goals by 15 percent.
5. The project applicant/permittee shall appoint a staff person appointed as Transportation Demand Management (TDM) coordinator to facilitate employees reducing solo-vehicle commuting and report to County staff on January 15 of each year (annual basis) on the status on the strategies implemented.

On Street Parking

6. Parking within the public right-of-way is prohibited during visitation, large marketing and/or temporary events

Landscaping Maintenance

7. Landscaping at the project driveway shall be maintained to not interfere with sight lines requires for safe stopping distance on the public-right-of-way. No items that are wide than 18 inches can be taller than 30 inches other than street trees and traffic control devices. Street trees should be deciduous and have branches lower than 4 feet in height up kept once the tree is established.

Encroachment Permit

8. An encroachment permit will be required for any improvements in the County's Right-of-Way. For the application submittal process contact the Roads Division at 707-944-0196. The improvements shall be constructed in compliance with the Napa County Road & Street Standards. The Registered Civil Engineer, upon completion of the improvements, must certify to the Department of Public Works that the improvements are made in accordance with all conditions of approval, including any related land use permit conditions and the approved improvement plans. Completion of improvements and certification shall be completed prior to occupancy or establishment of use. Please contact the Roads office at (707) 944-0196 to initiate the encroachment permit process. Any improvements located on Caltrans Right-of-Way will require a separate coordination and permitting process.

Please contact Ahsan Kazmi, P.E. Senior Traffic Engineer at Ahsan.Kazmi@countyofnapa.org or call (707) 259-8370 if you have any questions.



A Tradition of Stewardship
A Commitment to Service

Napa County Fire Department
Fire Marshal's Office
Hall of Justice, 2nd Floor
1125 3rd Street
Napa, CA 94559

Office: (707) 299-1466

Adam Mone
Fire Plans Examiner

MEMORANDUM

TO: Planning	DATE: 11/18/2021
FROM: Adam Mone, Plans Examiner	
SUBJECT: P19-00141 Venge Vineyards	020-350-043-000

The Napa County Fire Marshal's Office has reviewed the submittal package for the above proposed project. The Fire Marshal approves the project as submitted with the following conditions of approval:

1. All construction and use of the facility shall comply with all applicable standards, regulations, codes and ordinances at time of Building Permit issuance.
2. Beneficial occupancy will not be granted until all fire department fire and life safety items have been installed, tested and finalized.
3. All buildings, facilities, and developments shall be accessible to fire department apparatus by way of approved access roadways and/or driveways. The fire access road shall comply with the requirements of the Napa County Road & Street Standards and/or a valid road exception request supported by the Engineering Division.
4. Provide 100 feet of defensible space around all structures.
5. Provide 10 feet of defensible space fire hazard reduction on both sides of all roadways of the facility.

Please note that the comments noted above are based on a Fire Marshal review only. There may be additional comments or information requested from other County Departments or Divisions reviewing this application submittal package. Napa County Fire Marshal's Office Development Guidelines can be found @ www.countyofnapa.org/firemarshal. Should you have any questions of me, contact me at (707)299-1466 or email at adam.mone@countyofnapa.org